

**West Virginia Department of Environmental Protection  
Division of Air Quality**

Joe Manchin, III  
Governor

Randy C. Huffman  
Cabinet Secretary

# Permit to Operate



*Pursuant to*  
**Title V**  
*of the Clean Air Act*

*Issued to:*  
**Dominion Transmission, Inc.**  
**L.L.Tonkin Station / West Union**  
**R30-01700003-2010**

---

*John A. Benedict*  
*Director*

*Issued: June 7, 2010 • Effective: June 21, 2010*

*Expiration: June 7, 2015 • Renewal Application Due: December 7, 2014*

Permit Number: **R30-01700003-2010**  
Permittee: **Dominion Transmission, Inc.**  
Facility Name: L.L.Tonkin Station  
Permittee Mailing Address: 445 West Main Street, Clarksburg, WV 26301

---

*This permit is issued in accordance with the West Virginia Air Pollution Control Act (West Virginia Code §§ 22-5-1 et seq.) and 45CSR30 — Requirements for Operating Permits. The permittee identified at the above-referenced facility is authorized to operate the stationary sources of air pollutants identified herein in accordance with all terms and conditions of this permit.*

---

Facility Location:	West Union, Doddridge County, West Virginia
Facility Mailing Address:	HC69, Box 11, West Union, WV 26456
Telephone Number:	304-873-2641
Type of Business Entity:	Corporation
Facility Description:	Natural Gas Compressor Station
SIC Codes:	4922
UTM Coordinates:	518.82 km Easting • 4351.18 km Northing • Zone 17

Permit Writer: U.K.Bachhawat

*Any person whose interest may be affected, including, but not necessarily limited to, the applicant and any person who participated in the public comment process, by a permit issued, modified or denied by the Secretary may appeal such action of the Secretary to the Air Quality Board pursuant to article one [§§ 22B-1-1 et seq.], Chapter 22B of the Code of West Virginia. West Virginia Code §22-5-14.*

---

*Issuance of this Title V Operating Permit does not supersede or invalidate any existing permits under 45CSR13, 14 or 19, although all applicable requirements from such permits governing the facility's operation and compliance have been incorporated into the Title V Operating Permit.*

## Table of Contents

<b>1.0</b>	<b>Emission Units and Active R13, R14, and R19 Permits .....</b>	<b>4</b>
1.1.	Emission Units .....	4
1.2.	Active R13, R14, and R19 Permits .....	4
<b>2.0</b>	<b>General Conditions .....</b>	<b>5</b>
2.1.	Definitions .....	5
2.2.	Acronyms .....	5
2.3.	Permit Expiration and Renewal .....	6
2.4.	Permit Actions .....	6
2.5.	Reopening for Cause .....	6
2.6.	Administrative Permit Amendments .....	7
2.7.	Minor Permit Modifications .....	7
2.8.	Significant Permit Modification .....	7
2.9.	Emissions Trading .....	7
2.10.	Off-Permit Changes .....	7
2.11.	Operational Flexibility .....	8
2.12.	Reasonably Anticipated Operating Scenarios .....	9
2.13.	Duty to Comply .....	9
2.14.	Inspection and Entry .....	9
2.15.	Schedule of Compliance .....	10
2.16.	Need to Halt or Reduce Activity not a Defense .....	10
2.17.	Emergency .....	10
2.18.	Federally-Enforceable Requirements .....	11
2.19.	Duty to Provide Information .....	11
2.20.	Duty to Supplement and Correct Information .....	11
2.21.	Permit Shield .....	11
2.22.	Credible Evidence .....	12
2.23.	Severability .....	12
2.24.	Property Rights .....	12
2.25.	Acid Deposition Control .....	12
<b>3.0</b>	<b>Facility-Wide Requirements .....</b>	<b>14</b>
3.1.	Limitations and Standards .....	14
3.2.	Monitoring Requirements .....	16
3.3.	Testing Requirements .....	16
3.4.	Recordkeeping Requirements .....	17
3.5.	Reporting Requirements .....	18
3.6.	Compliance Plan .....	20
3.7.	Permit Shield .....	20
3.8.	Emergency Operating Scenario .....	20
<b>APPENDIX A</b>	<b>.....</b>	<b>21</b>

## 1.0 Emission Units and Active R13, R14, and R19 Permits

### 1.1 Emission Units

Emission Unit ID	Emission Point ID	Emission Unit Description	Year Installed	Design Capacity	Control Device
001-01*	TRB01	Turbine; Solar T-4500	1989	4390 HP	N/A
002-01*	AUX01	Reciprocating Engine/Auxiliary Generator; Cummins GTA-743	1989	169 HP	N/A
004-01*	BLR01	Boiler; Peerless G-14691-WS-I	1989	0.52 MMBtu/hr	N/A
TK01	TK01	Horizontal Aboveground Storage Tank – Drip Gas	1989	3,000 – gallon	N/A
TK02	TK02	Horizontal Aboveground Storage Tank – Used Oil	1989	1,000 – gallon	N/A
TK03	TK03	Horizontal Aboveground Storage Tank – Motor Oil	1989	500 - gallon	N/A

\* This equipment burns or combusts pipeline quality natural gas only.

### 1.2 Active R13, R14, and R19 Permits

The underlying authority for any conditions from R13, R14, and/or R19 permits contained in this operating permit is cited using the original permit number (e.g. R13-1234). The current applicable version of such permit(s) is listed below.

Permit Number	Date of Issuance
R13-1077	4/7/1989

## 2.0 General Conditions

### 2.1. Definitions

- 2.1.1. All references to the "West Virginia Air Pollution Control Act" or the "Air Pollution Control Act" mean those provisions contained in W.Va. Code §§ 22-5-1 to 22-5-18.
- 2.1.2. The "Clean Air Act" means those provisions contained in 42 U.S.C. §§ 7401 to 7671q, and regulations promulgated thereunder.
- 2.1.3. "Secretary" means the Secretary of the Department of Environmental Protection or such other person to whom the Secretary has delegated authority or duties pursuant to W.Va. Code §§ 22-1-6 or 22-1-8 (45CSR§30-2.12.). The Director of the Division of Air Quality is the Secretary's designated representative for the purposes of this permit.
- 2.1.4. Unless otherwise specified in a permit condition or underlying rule or regulation, all references to a "rolling yearly total" or "rolling total emissions" shall mean the sum of the monthly data, values or parameters being measured, monitored, or recorded, at any given time for the previous twelve (12) consecutive calendar months.

### 2.2. Acronyms

<b>CAAA</b>	Clean Air Act Amendments	<b>NO<sub>x</sub></b>	Nitrogen Oxides
<b>CBI</b>	Confidential Business Information	<b>NSPS</b>	New Source Performance
<b>CEM</b>	Continuous Emission Monitor		Standards
<b>CES</b>	Certified Emission Statement	<b>PM</b>	Particulate Matter
<b>C.F.R. or CFR</b>	Code of Federal Regulations	<b>PM<sub>10</sub></b>	Particulate Matter less than
<b>CO</b>	Carbon Monoxide		10µm in diameter
<b>C.S.R. or CSR</b>	Codes of State Rules	<b>pph</b>	Pounds per Hour
<b>DAQ</b>	Division of Air Quality	<b>ppm</b>	Parts per Million
<b>DEP</b>	Department of Environmental Protection	<b>PSD</b>	Prevention of Significant Deterioration
<b>FOIA</b>	Freedom of Information Act	<b>psi</b>	Pounds per Square Inch
<b>HAP</b>	Hazardous Air Pollutant	<b>SIC</b>	Standard Industrial Classification
<b>HON</b>	Hazardous Organic NESHAP		
<b>HP</b>	Horsepower	<b>SIP</b>	State Implementation Plan
<b>lbs/hr or lb/hr</b>	Pounds per Hour	<b>SO<sub>2</sub></b>	Sulfur Dioxide
<b>LDAR</b>	Leak Detection and Repair	<b>TAP</b>	Toxic Air Pollutant
<b>m</b>	Thousand	<b>TPY</b>	Tons per Year
<b>MACT</b>	Maximum Achievable Control Technology	<b>TRS</b>	Total Reduced Sulfur
		<b>TSP</b>	Total Suspended Particulate
<b>mm</b>	Million	<b>USEPA</b>	United States Environmental Protection Agency
<b>mmBtu/hr</b>	Million British Thermal Units per Hour		
<b>mmft<sup>3</sup>/hr or mmcf/hr</b>	Million Cubic Feet Burned per Hour	<b>UTM</b>	Universal Transverse Mercator
<b>NA or N/A</b>	Not Applicable	<b>VEE</b>	Visual Emissions Evaluation
<b>NAAQS</b>	National Ambient Air Quality Standards	<b>VOC</b>	Volatile Organic Compounds
<b>NESHAPS</b>	National Emissions Standards for Hazardous Air Pollutants		

### **2.3. Permit Expiration and Renewal**

- 2.3.1. Permit duration. This permit is issued for a fixed term of five (5) years and shall expire on the date specified on the cover of this permit, except as provided in 45CSR§30-6.3.b. and 45CSR§30-6.3.c.  
**[45CSR§30-5.1.b.]**
- 2.3.2. A permit renewal application is timely if it is submitted at least six (6) months prior to the date of permit expiration.  
**[45CSR§30-4.1.a.3.]**
- 2.3.3. Permit expiration terminates the source's right to operate unless a timely and complete renewal application has been submitted consistent with 45CSR§30-6.2. and 45CSR§30-4.1.a.3.  
**[45CSR§30-6.3.b.]**
- 2.3.4. If the Secretary fails to take final action to deny or approve a timely and complete permit application before the end of the term of the previous permit, the permit shall not expire until the renewal permit has been issued or denied, and any permit shield granted for the permit shall continue in effect during that time.  
**[45CSR§30-6.3.c.]**

### **2.4. Permit Actions**

- 2.4.1. This permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition.  
**[45CSR§30-5.1.f.3.]**

### **2.5. Reopening for Cause**

- 2.5.1. This permit shall be reopened and revised under any of the following circumstances:
  - a. Additional applicable requirements under the Clean Air Act or the Secretary's legislative rules become applicable to a major source with a remaining permit term of three (3) or more years. Such a reopening shall be completed not later than eighteen (18) months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which the permit is due to expire, unless the original permit or any of its terms and conditions has been extended pursuant to 45CSR§§30-6.6.a.1.A. or B.
  - b. Additional requirements (including excess emissions requirements) become applicable to an affected source under Title IV of the Clean Air Act (Acid Deposition Control) or other legislative rules of the Secretary. Upon approval by U.S. EPA, excess emissions offset plans shall be incorporated into the permit.
  - c. The Secretary or U.S. EPA determines that the permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the permit.
  - d. The Secretary or U.S. EPA determines that the permit must be revised or revoked and reissued to assure compliance with the applicable requirements.

**[45CSR§30-6.6.a.]**

## **2.6. Administrative Permit Amendments**

- 2.6.1. The permittee may request an administrative permit amendment as defined in and according to the procedures specified in 45CSR§30-6.4.  
[45CSR§30-6.4.]

## **2.7. Minor Permit Modifications**

- 2.7.1. The permittee may request a minor permit modification as defined in and according to the procedures specified in 45CSR§30-6.5.a.  
[45CSR§30-6.5.a.]

## **2.8. Significant Permit Modification**

- 2.8.1. The permittee may request a significant permit modification, in accordance with 45CSR§30-6.5.b., for permit modifications that do not qualify for minor permit modifications or as administrative amendments.  
[45CSR§30-6.5.b.]

## **2.9. Emissions Trading**

- 2.9.1. No permit revision shall be required, under any approved economic incentives, marketable permits, emissions trading, and other similar programs or processes for changes that are provided for in the permit and that are in accordance with all applicable requirements.  
[45CSR§30-5.1.h.]

## **2.10. Off-Permit Changes**

- 2.10.1. Except as provided below, a facility may make any change in its operations or emissions that is not addressed nor prohibited in its permit and which is not considered to be construction nor modification under any rule promulgated by the Secretary without obtaining an amendment or modification of its permit. Such changes shall be subject to the following requirements and restrictions:
- a. The change must meet all applicable requirements and may not violate any existing permit term or condition.
  - b. The permittee must provide a written notice of the change to the Secretary and to U.S. EPA within two (2) business days following the date of the change. Such written notice shall describe each such change, including the date, any change in emissions, pollutants emitted, and any applicable requirement that would apply as a result of the change.
  - c. The change shall not qualify for the permit shield.
  - d. The permittee shall keep records describing all changes made at the source that result in emissions of regulated air pollutants, but not otherwise regulated under the permit, and the emissions resulting from those changes.
  - e. No permittee may make any change subject to any requirement under Title IV of the Clean Air Act (Acid Deposition Control) pursuant to the provisions of 45CSR§30-5.9.

- f. No permittee may make any changes which would require preconstruction review under any provision of Title I of the Clean Air Act (including 45CSR14 and 45CSR19) pursuant to the provisions of 45CSR§30-5.9.

**[45CSR§30-5.9.]**

**2.11. Operational Flexibility**

- 2.11.1. The permittee may make changes within the facility as provided by § 502(b)(10) of the Clean Air Act. Such operational flexibility shall be provided in the permit in conformance with the permit application and applicable requirements. No such changes shall be a modification under any rule or any provision of Title I of the Clean Air Act (including 45CSR14 and 45CSR19) promulgated by the Secretary in accordance with Title I of the Clean Air Act and the change shall not result in a level of emissions exceeding the emissions allowable under the permit.

**[45CSR§30-5.8]**

- 2.11.2. Before making a change under 45CSR§30-5.8., the permittee shall provide advance written notice to the Secretary and to U.S. EPA, describing the change to be made, the date on which the change will occur, any changes in emissions, and any permit terms and conditions that are affected. The permittee shall thereafter maintain a copy of the notice with the permit, and the Secretary shall place a copy with the permit in the public file. The written notice shall be provided to the Secretary and U.S. EPA at least seven (7) days prior to the date that the change is to be made, except that this period may be shortened or eliminated as necessary for a change that must be implemented more quickly to address unanticipated conditions posing a significant health, safety, or environmental hazard. If less than seven (7) days notice is provided because of a need to respond more quickly to such unanticipated conditions, the permittee shall provide notice to the Secretary and U.S. EPA as soon as possible after learning of the need to make the change.

**[45CSR§30-5.8.a.]**

- 2.11.3. The permit shield shall not apply to changes made under 45CSR§30-5.8., except those provided for in 45CSR§30-5.8.d. However, the protection of the permit shield will continue to apply to operations and emissions that are not affected by the change, provided that the permittee complies with the terms and conditions of the permit applicable to such operations and emissions. The permit shield may be reinstated for emissions and operations affected by the change:

- a. If subsequent changes cause the facility's operations and emissions to revert to those authorized in the permit and the permittee resumes compliance with the terms and conditions of the permit, or
- b. If the permittee obtains final approval of a significant modification to the permit to incorporate the change in the permit.

**[45CSR§30-5.8.c.]**

- 2.11.4. "Section 502(b)(10) changes" are changes that contravene an express permit term. Such changes do not include changes that would violate applicable requirements or contravene enforceable permit terms and conditions that are monitoring (including test methods), recordkeeping, reporting, or compliance certification requirements.

**[45CSR§30-2.39]**

## **2.12. Reasonably Anticipated Operating Scenarios**

2.12.1. The following are terms and conditions for reasonably anticipated operating scenarios identified in this permit.

- a. Contemporaneously with making a change from one operating scenario to another, the permittee shall record in a log at the permitted facility a record of the scenario under which it is operating and to document the change in reports submitted pursuant to the terms of this permit and 45CSR30.
- b. The permit shield shall extend to all terms and conditions under each such operating scenario; and
- c. The terms and conditions of each such alternative scenario shall meet all applicable requirements and the requirements of 45CSR30.

**[45CSR§30-5.1.i.]**

## **2.13. Duty to Comply**

2.13.1. The permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the West Virginia Code and the Clean Air Act and is grounds for enforcement action by the Secretary or USEPA; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.

**[45CSR§30-5.1.f.1.]**

## **2.14. Inspection and Entry**

2.14.1. The permittee shall allow any authorized representative of the Secretary, upon the presentation of credentials and other documents as may be required by law, to perform the following:

- a. At all reasonable times (including all times in which the facility is in operation) enter upon the permittee's premises where a source is located or emissions related activity is conducted, or where records must be kept under the conditions of this permit;
- b. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
- c. Inspect at reasonable times (including all times in which the facility is in operation) any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under the permit;
- d. Sample or monitor at reasonable times substances or parameters to determine compliance with the permit or applicable requirements or ascertain the amounts and types of air pollutants discharged.

**[45CSR§30-5.3.b.]**

## **2.15. Schedule of Compliance**

- 2.15.1. For sources subject to a compliance schedule, certified progress reports shall be submitted consistent with the applicable schedule of compliance set forth in this permit and 45CSR§30-4.3.h., but at least every six (6) months, and no greater than once a month, and shall include the following:
- a. Dates for achieving the activities, milestones, or compliance required in the schedule of compliance, and dates when such activities, milestones or compliance were achieved; and
  - b. An explanation of why any dates in the schedule of compliance were not or will not be met, and any preventative or corrective measure adopted.

**[45CSR§30-5.3.d.]**

## **2.16. Need to Halt or Reduce Activity not a Defense**

- 2.16.1. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit. However, nothing in this paragraph shall be construed as precluding consideration of a need to halt or reduce activity as a mitigating factor in determining penalties for noncompliance if the health, safety, or environmental impacts of halting or reducing operations would be more serious than the impacts of continued operations.

**[45CSR§30-5.1.f.2.]**

## **2.17. Emergency**

- 2.17.1. An "emergency" means any situation arising from sudden and reasonably unforeseeable events beyond the control of the source, including acts of God, which situation requires immediate corrective action to restore normal operation, and that causes the source to exceed a technology-based emission limitation under the permit, due to unavoidable increases in emissions attributable to the emergency. An emergency shall not include noncompliance to the extent caused by improperly designed equipment, lack of preventative maintenance, careless or improper operation, or operator error.

**[45CSR§30-5.7.a.]**

- 2.17.2. Effect of any emergency. An emergency constitutes an affirmative defense to an action brought for noncompliance with such technology-based emission limitations if the conditions of 45CSR§30-5.7.c. are met.

**[45CSR§30-5.7.b.]**

- 2.17.3. The affirmative defense of emergency shall be demonstrated through properly signed, contemporaneous operating logs, or other relevant evidence that:

- a. An emergency occurred and that the permittee can identify the cause(s) of the emergency;
- b. The permitted facility was at the time being properly operated;
- c. During the period of the emergency the permittee took all reasonable steps to minimize levels of emissions that exceeded the emission standards, or other requirements in the permit; and

- d. Subject to the requirements of 45CSR§30-5.1.c.3.C.1, the permittee submitted notice of the emergency to the Secretary within one (1) working day of the time when emission limitations were exceeded due to the emergency and made a request for variance, and as applicable rules provide. This notice, report, and variance request fulfills the requirement of 45CSR§30-5.1.c.3.B. This notice must contain a detailed description of the emergency, any steps taken to mitigate emissions, and corrective actions taken.

**[45CSR§30-5.7.c.]**

- 2.17.4. In any enforcement proceeding, the permittee seeking to establish the occurrence of an emergency has the burden of proof.

**[45CSR§30-5.7.d.]**

- 2.17.5. This provision is in addition to any emergency or upset provision contained in any applicable requirement.

**[45CSR§30-5.7.e.]**

## **2.18. Federally-Enforceable Requirements**

- 2.18.1. All terms and conditions in this permit, including any provisions designed to limit a source's potential to emit and excepting those provisions that are specifically designated in the permit as "State-enforceable only", are enforceable by the Secretary, USEPA, and citizens under the Clean Air Act.

**[45CSR§30-5.2.a.]**

- 2.18.2. Those provisions specifically designated in the permit as "State-enforceable only" shall become "Federally-enforceable" requirements upon SIP approval by the USEPA.

## **2.19. Duty to Provide Information**

- 2.19.1. The permittee shall furnish to the Secretary within a reasonable time any information the Secretary may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the Secretary copies of records required to be kept by the permittee. For information claimed to be confidential, the permittee shall furnish such records to the Secretary along with a claim of confidentiality in accordance with 45CSR31. If confidential information is to be sent to USEPA, the permittee shall directly provide such information to USEPA along with a claim of confidentiality in accordance with 40 C.F.R. Part 2.

**[45CSR§30-5.1.f.5.]**

## **2.20. Duty to Supplement and Correct Information**

- 2.20.1. Upon becoming aware of a failure to submit any relevant facts or a submittal of incorrect information in any permit application, the permittee shall promptly submit to the Secretary such supplemental facts or corrected information.

**[45CSR§30-4.2.]**

## **2.21. Permit Shield**

- 2.21.1. Compliance with the conditions of this permit shall be deemed compliance with any applicable requirements as of the date of permit issuance provided that such applicable requirements are included and are specifically

identified in this permit or the Secretary has determined that other requirements specifically identified are not applicable to the source and this permit includes such a determination or a concise summary thereof.

**[45CSR§30-5.6.a.]**

2.21.2. Nothing in this permit shall alter or affect the following:

- a. The liability of an owner or operator of a source for any violation of applicable requirements prior to or at the time of permit issuance; or
- b. The applicable requirements of the Code of West Virginia and Title IV of the Clean Air Act (Acid Deposition Control), consistent with § 408 (a) of the Clean Air Act.
- c. The authority of the Administrator of U.S. EPA to require information under § 114 of the Clean Air Act or to issue emergency orders under § 303 of the Clean Air Act.

**[45CSR§30-5.6.c.]**

## **2.22. Credible Evidence**

2.22.1. Nothing in this permit shall alter or affect the ability of any person to establish compliance with, or a violation of, any applicable requirement through the use of credible evidence to the extent authorized by law. Nothing in this permit shall be construed to waive any defenses otherwise available to the permittee including but not limited to any challenge to the credible evidence rule in the context of any future proceeding.

**[45CSR§30-5.3.e.3.B. and 45CSR38]**

## **2.23. Severability**

2.23.1. The provisions of this permit are severable. If any provision of this permit, or the application of any provision of this permit to any circumstance is held invalid by a court of competent jurisdiction, the remaining permit terms and conditions or their application to other circumstances shall remain in full force and effect.

**[45CSR§30-5.1.e.]**

## **2.24. Property Rights**

2.24.1. This permit does not convey any property rights of any sort or any exclusive privilege.

**[45CSR§30-5.1.f.4]**

## **2.25. Acid Deposition Control**

2.25.1. Emissions shall not exceed any allowances that the source lawfully holds under Title IV of the Clean Air Act (Acid Deposition Control) or rules of the Secretary promulgated thereunder.

- a. No permit revision shall be required for increases in emissions that are authorized by allowances acquired pursuant to the acid deposition control program, provided that such increases do not require a permit revision under any other applicable requirement.
- b. No limit shall be placed on the number of allowances held by the source. The source may not, however, use allowances as a defense to noncompliance with any other applicable requirement.

- c. Any such allowance shall be accounted for according to the procedures established in rules promulgated under Title IV of the Clean Air Act.

**[45CSR§30-5.1.d.]**

- 2.25.2. Where applicable requirements of the Clean Air Act are more stringent than any applicable requirement of regulations promulgated under Title IV of the Clean Air Act (Acid Deposition Control), both provisions shall be incorporated into the permit and shall be enforceable by the Secretary and U. S. EPA.

**[45CSR§30-5.1.a.2.]**

### 3.0 Facility-Wide Requirements

#### 3.1. Limitations and Standards

- 3.1.1. **Open burning.** The open burning of refuse by any person is prohibited except as noted in 45CSR§6-3.1.  
[45CSR§6-3.1.]
- 3.1.2. **Open burning exemptions.** The exemptions listed in 45CSR§6-3.1 are subject to the following stipulation: Upon notification by the Secretary, no person shall cause or allow any form of open burning during existing or predicted periods of atmospheric stagnation. Notification shall be made by such means as the Secretary may deem necessary and feasible.  
[45CSR§6-3.2.]
- 3.1.3. **Asbestos.** The permittee is responsible for thoroughly inspecting the facility, or part of the facility, prior to commencement of demolition or renovation for the presence of asbestos and complying with 40 C.F.R. § 61.145, 40 C.F.R. § 61.148, and 40 C.F.R. § 61.150. The permittee, owner, or operator must notify the Secretary at least ten (10) working days prior to the commencement of any asbestos removal on the forms prescribed by the Secretary if the permittee is subject to the notification requirements of 40 C.F.R. § 61.145(b)(3)(i). The USEPA, the Division of Waste Management and the Bureau for Public Health - Environmental Health require a copy of this notice to be sent to them.  
[40 C.F.R. §61.145(b) and 45CSR34]
- 3.1.4. **Odor.** No person shall cause, suffer, allow or permit the discharge of air pollutants which cause or contribute to an objectionable odor at any location occupied by the public.  
[45CSR§4-3.1 State-Enforceable only.]
- 3.1.5. **Standby plan for reducing emissions.** When requested by the Secretary, the permittee shall prepare standby plans for reducing the emissions of air pollutants in accordance with the objectives set forth in Tables I, II, and III of 45CSR11.  
[45CSR§11-5.2]
- 3.1.6. **Emission inventory.** The permittee is responsible for submitting, on an annual basis, an emission inventory in accordance with the submittal requirements of the Division of Air Quality.  
[W.Va. Code § 22-5-4(a)(14)]
- 3.1.7. **Ozone-depleting substances.** For those facilities performing maintenance, service, repair or disposal of appliances, the permittee shall comply with the standards for recycling and emissions reduction pursuant to 40 C.F.R. Part 82, Subpart F, except as provided for Motor Vehicle Air Conditioners (MVACs) in Subpart B:
- a. Persons opening appliances for maintenance, service, repair, or disposal must comply with the prohibitions and required practices pursuant to 40 C.F.R. §§ 82.154 and 82.156.
  - b. Equipment used during the maintenance, service, repair, or disposal of appliances must comply with the standards for recycling and recovery equipment pursuant to 40 C.F.R. § 82.158.
  - c. Persons performing maintenance, service, repair, or disposal of appliances must be certified by an approved technician certification program pursuant to 40 C.F.R. § 82.161.

[40 C.F.R. 82, Subpart F]

- 3.1.8. **Risk Management Plan.** Should this stationary source, as defined in 40 C.F.R. § 68.3, become subject to Part 68, then the owner or operator shall submit a risk management plan (RMP) by the date specified in 40 C.F.R. § 68.10 and shall certify compliance with the requirements of Part 68 as part of the annual compliance certification as required by 40 C.F.R. Part 70 or 71.

**[40 C.F.R. 68]**

- 3.1.9. No person shall cause, suffer, allow or permit emission of smoke and/or particulate matter into the open air from any fuel burning unit which is greater than ten (10) percent opacity based on a six minute block average.

**[45CSR§2-3.1.] [BLR01]**

- 3.1.10. Emissions of the below pollutants to the atmosphere resulting from the operation of the natural gas-fired turbine herein shall not exceed:

	Lb/hr	TPY
NO <sub>x</sub>	22.6	99.0
CO	3.8	16.6
VOC	1.4	6.1
SO <sub>2</sub>	0.04	0.18

**[45CSR13, R13-1077, A] [TRB01]**

- 3.1.11. The permittee is responsible for complying with 40 C.F.R. § 60.332, 40 C.F.R. § 60.333, 40 C.F.R. § 60.334, and 40 C.F.R. § 60.335. The permittee must notify the Director of the DAQ of excess emissions as required.

**[45CSR13, R13-1077, B.1; 40 C.F.R. 60 Subpart GG; 45CSR16] [TRB01]**

(Note: Applicable requirements from 40 C.F.R. 60 Subpart GG is included in Appendix A)

- 3.1.12. a. No person shall cause, suffer, allow or permit fugitive particulate matter to be discharged beyond the boundary lines of the property on which the discharge originates or at any public or residential location, which causes or contributes to statutory air pollution.
- b. When a person is found in violation of 45CSR17, the Director may require the person to utilize a system to minimize fugitive particulate matter. This system to minimize fugitive particulate matter may include, but is not limited to, the following:
- Use, where practicable, of water or chemicals for control of particulate matter in demolition of existing buildings or structures, construction operations, grading of roads or the clearing of land;
  - Application of asphalt, water or suitable chemicals on unpaved roads, material stockpiles and other surfaces which can create airborne particulate matter;
  - Covering of material transport vehicles, or treatment of cargo, to prevent contents from dripping, sifting, leaking or otherwise escaping and becoming airborne, and prompt removal of tracked material from roads or streets; or
  - Installation and use of hoods, fans and fabric filters to enclose and vent the handling of materials, including adequate containment methods during sandblasting, abrasive cleaning or other similar operations.

**[45CSR§17-3]**

### 3.2. Monitoring Requirements

- 3.2.1. Monthly emissions from the turbine shall be calculated by the 15<sup>th</sup> day of the subsequent month utilizing the equations listed below to show compliance with Section 3.1.10:

*NO<sub>x</sub> Emission Rate:*

4390 hp x (2.277 gm/bhp-hr) x (Operating Hours/month) x (11b/453.6 gm) x (1 ton/2000 lb) = tons/month

*CO Emission Rate:*

4390 hp x (0.383 gm/bhp-hr) x (Operating Hours/month) x (11b/453.6 gm) x (1 ton/2000 lb) = tons/month

*SO<sub>2</sub> Emission Rate:*

4390 hp x (0.004 gm/bhp-hr) x (Operating Hours/month) x (11b/453.6 gm) x (1 ton/2000 lb) = tons/month

*VOC Emission Rate:*

4390 hp x (0.141 gm/bhp-hr) x (Operating Hours/month) x (11b/453.6 gm) x (1 ton/2000 lb) = tons/month

A twelve month running total of emissions shall be maintained to verify compliance with the long term emission limitations. Each month a new twelve month total shall be calculated using the previous twelve months data. Compliance with the hourly emission limits shall be demonstrated by converting to pounds and dividing by the monthly calculated emissions by the number of operating hours in the previous month to obtain an hourly average. Records indicating the hourly and twelve month rolling total emissions shall be maintained on site or at a reasonably available location.

**[45CSR§30-5.1.c.] [TRB01]**

- 3.2.2. Monitoring of fuel nitrogen shall not be required while natural gas is the only fuel fired in the gas turbine.  
**[45CSR13, R13-1077, B.2] [TRB01]**
- 3.2.3. Analysis for fuel sulfur content of the natural gas shall be conducted using one of the approved ASTM reference methods for the measurement of sulfur in gaseous fuels, as referenced in 40 C.F.R. § 60.335. Sample analysis shall be conducted twice per annum during the first and third quarters of each calendar year. Should any sulfur analysis indicate noncompliance with 40 C.F.R. § 60.333, the owner or operator shall notify the Director of the Division of Air Quality of such excess emissions and the schedule shall be re-examined by the USEPA. Sulfur monitoring shall be conducted weekly during the interim period when this schedule is being re-examined.  
**[45CSR13, R13-1077, B.3] [TRB01]**
- 3.2.4. If there is a change in fuel supply, the owner or operator must notify the State of such change for re-examination of this custom schedule outlined in 3.2.3. A substantial change in fuel quality shall be considered as a change in fuel supply. Sulfur monitoring shall be conducted weekly during the interim period when this custom schedule is being re-examined. **[45CSR13, R13-1077, B.4] [TRB01]**

### 3.3. Testing Requirements

- 3.3.1. **Stack testing.** As per provisions set forth in this permit or as otherwise required by the Secretary, in accordance with the West Virginia Code, underlying regulations, permits and orders, the permittee shall conduct test(s) to determine compliance with the emission limitations set forth in this permit and/or established or set forth in underlying documents. The Secretary, or his duly authorized representative, may at his option witness or conduct such test(s). Should the Secretary exercise his option to conduct such test(s), the operator shall provide all necessary sampling connections and sampling ports to be located in such manner as the Secretary may require, power for test equipment and the required safety equipment, such as scaffolding, railings and ladders, to comply with generally accepted good safety practices. Such tests shall be conducted in accordance with the methods and procedures set forth in this permit or as otherwise approved or specified by the Secretary in accordance with the following:

- a. The Secretary may on a source-specific basis approve or specify additional testing or alternative testing to the test methods specified in the permit for demonstrating compliance with 40 C.F.R. Parts 60, 61, and 63, if applicable, in accordance with the Secretary's delegated authority and any established equivalency determination methods which are applicable.
- b. The Secretary may on a source-specific basis approve or specify additional testing or alternative testing to the test methods specified in the permit for demonstrating compliance with applicable requirements which do not involve federal delegation. In specifying or approving such alternative testing to the test methods, the Secretary, to the extent possible, shall utilize the same equivalency criteria as would be used in approving such changes under Section 3.3.1.a. of this permit.
- c. All periodic tests to determine mass emission limits from or air pollutant concentrations in discharge stacks and such other tests as specified in this permit shall be conducted in accordance with an approved test protocol. Unless previously approved, such protocols shall be submitted to the Secretary in writing at least thirty (30) days prior to any testing and shall contain the information set forth by the Secretary. In addition, the permittee shall notify the Secretary at least fifteen (15) days prior to any testing so the Secretary may have the opportunity to observe such tests. This notification shall include the actual date and time during which the test will be conducted and, if appropriate, verification that the tests will fully conform to a referenced protocol previously approved by the Secretary.

[WV Code § 22-5-4(a)(15) and 45CSR13]

### **3.4. Recordkeeping Requirements**

- 3.4.1. **Monitoring information.** The permittee shall keep records of monitoring information that include the following:
  - a. The date, place as defined in this permit and time of sampling or measurements;
  - b. The date(s) analyses were performed;
  - c. The company or entity that performed the analyses;
  - d. The analytical techniques or methods used;
  - e. The results of the analyses; and
  - f. The operating conditions existing at the time of sampling or measurement.

[45CSR§30-5.1.c.2.A.]

- 3.4.2. **Retention of records.** The permittee shall retain records of all required monitoring data and support information for a period of at least five (5) years from the date of monitoring sample, measurement, report, application, or record creation date. Support information includes all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit. Where appropriate, records may be maintained in computerized form in lieu of the above records. [45CSR§30-5.1.c.2.B.]

- 3.4.3. **Odors.** For the purposes of 45CSR4, the permittee shall maintain a record of all odor complaints received, any investigation performed in response to such a complaint, and any responsive action(s) taken.  
[45CSR§30-5.1.c. State-Enforceable only.]
- 3.4.4. Records of sample analysis and fuel supply pertinent to the custom schedule outlined in 3.2.3 shall be retained for a period of three years, and be available for inspection by personnel of federal, state and local air pollution control agencies.  
[45CSR13, R13-1077, B.5] [TRB01]

### 3.5. Reporting Requirements

- 3.5.1. **Responsible official.** Any application form, report, or compliance certification required by this permit to be submitted to the DAQ and/or USEPA shall contain a certification by the responsible official that states that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate and complete. [45CSR§§30-4.4. and 5.1.c.3.D.]
- 3.5.2. A permittee may request confidential treatment for the submission of reporting required under 45CSR§30-5.1.c.3. pursuant to the limitations and procedures of W.Va. Code § 22-5-10 and 45CSR31.  
[45CSR§30-5.1.c.3.E.]
- 3.5.3. Except for the electronic submittal of the annual certification to the USEPA as required in 3.5.5 below, all notices, requests, demands, submissions and other communications required or permitted to be made to the Secretary of DEP and/or USEPA shall be made in writing and shall be deemed to have been duly given when delivered by hand, mailed first class or by private carrier with postage prepaid to the address(es) set forth below or to such other person or address as the Secretary of the Department of Environmental Protection may designate:

#### If to the DAQ:

Director  
WVDEP  
Division of Air Quality  
601 57<sup>th</sup> Street SE  
Charleston, WV 25304  
  
Phone: 304/926-0475  
FAX: 304/926-0478

#### If to the US EPA:

Associate Director  
Office of Enforcement and Permits Review  
(3AP12)  
U. S. Environmental Protection Agency  
Region III  
1650 Arch Street  
Philadelphia, PA 19103-2029

- 3.5.4. **Certified emissions statement.** The permittee shall submit a certified emissions statement and pay fees on an annual basis in accordance with the submittal requirements of the Division of Air Quality.  
[45CSR§30-8.]
- 3.5.5. **Compliance certification.** The permittee shall certify compliance with the conditions of this permit on the forms provided by the DAQ. In addition to the annual compliance certification, the permittee may be required to submit certifications more frequently under an applicable requirement of this permit. The annual certification shall be submitted to the DAQ and USEPA on or before March 15 of each year, and shall certify compliance for

the period ending December 31. The annual certification to the USEPA shall be submitted in electronic format only. It shall be submitted by e-mail to the following address: [R3\\_APD\\_Permits@epa.gov](mailto:R3_APD_Permits@epa.gov). The permittee shall maintain a copy of the certification on site for five (5) years from submittal of the certification.

[45CSR§30-5.3.e.]

- 3.5.6. **Semi-annual monitoring reports.** The permittee shall submit reports of any required monitoring on or before September 15 for the reporting period January 1 to June 30 and on or before March 15 for the reporting period July 1 to December 31. All instances of deviation from permit requirements must be clearly identified in such reports. All required reports must be certified by a responsible official consistent with 45CSR§30-4.4.

[45CSR§30-5.1.c.3.A.]

- 3.5.7. **Emergencies.** For reporting emergency situations, refer to Section 2.17 of this permit.

- 3.5.8. **Deviations.**

- a. In addition to monitoring reports required by this permit, the permittee shall promptly submit supplemental reports and notices in accordance with the following:

1. Any deviation resulting from an emergency or upset condition, as defined in 45CSR§30-5.7., shall be reported by telephone or telefax within one (1) working day of the date on which the permittee becomes aware of the deviation, if the permittee desires to assert the affirmative defense in accordance with 45CSR§30-5.7. A written report of such deviation, which shall include the probable cause of such deviations, and any corrective actions or preventative measures taken, shall be submitted and certified by a responsible official within ten (10) days of the deviation.
2. Any deviation that poses an imminent and substantial danger to public health, safety, or the environment shall be reported to the Secretary immediately by telephone or telefax. A written report of such deviation, which shall include the probable cause of such deviation, and any corrective actions or preventative measures taken, shall be submitted by the responsible official within ten (10) days of the deviation.
3. Deviations for which more frequent reporting is required under this permit shall be reported on the more frequent basis.
4. All reports of deviations shall identify the probable cause of the deviation and any corrective actions or preventative measures taken.

[45CSR§30-5.1.c.3.C.]

- b. The permittee shall, in the reporting of deviations from permit requirements, including those attributable to upset conditions as defined in this permit, report the probable cause of such deviations and any corrective actions or preventive measures taken in accordance with any rules of the Secretary.

[45CSR§30-5.1.c.3.B.]

- 3.5.9. **New applicable requirements.** If any applicable requirement is promulgated during the term of this permit, the permittee will meet such requirements on a timely basis, or in accordance with a more detailed schedule if required by the applicable requirement.

[45CSR§30-4.3.h.1.B.]

### **3.6. Compliance Plan**

- 3.6.1. N/A

### **3.7. Permit Shield**

- 3.7.1. The permittee is hereby granted a permit shield in accordance with 45CSR§30-5.6. The permit shield applies provided the permittee operates in accordance with the information contained within this permit.
- 3.7.2. The following requirements specifically identified are not applicable to the source based on the determinations set forth below. The permit shield shall apply to the following requirements provided the conditions of the determinations are met.
- a. N/A

### **3.8. Emergency Operating Scenario**

- 3.8.1. For emergency situations which interrupt the critical supply of natural gas to the public, and which pose a life threatening circumstance to the customer, the permittee is allowed to temporarily replace failed engine(s) as long as all of the following conditions are met:
- a. The replacement engine(s) is only allowed to operate until repair of the failed engine(s) is complete, but under no circumstance may the replacement engine(s) operate in excess of sixty (60) days;
  - b. Both the replacement engine(s) and the repaired failed engine(s) shall not operate at the same time with the exception of any necessary testing of the repaired engine(s) and this testing may not exceed five (5) hours;
  - c. Potential hourly emissions from the replacement engine(s) are less than or equal to the potential hourly emissions from the engine(s) being replaced;
  - d. Credible performance emission test data verifying the emission rates associated with the operation of the substitute engine shall be submitted to the Director within five (5) days if requested by the Director;
  - e. The permittee must provide written notification to the Director within five (5) days of the replacement. This notification must contain:
    - i. Information to support the claim of life threatening circumstances to justify applicability of this emergency provision;
    - ii. Identification of the engine(s) being temporarily replaced;
    - iii. The design parameters of the replacement engine(s) including, but not limited to, the design horsepower and emission factors;
    - iv. Projected duration of the replacement engine(s); and
    - v. The appropriate certification by a responsible official.

## Appendix A

The following reflect 40 C.F.R. 60 Subpart GG requirements as of January 27, 2010 and are subject to change.

### 40 C.F.R. § 60.332 ; Standard for nitrogen oxides.

- (a) On and after the date on which the performance test required by §60.8 is completed, every owner or operator subject to the provisions of this subpart as specified in paragraphs (b), (c), and (d) of this section shall comply with one of the following, except as provided in paragraphs (e), (f), (g), (h), (i), (j), (k), and (l) of this section.

- (1) No owner or operator subject to the provisions of this subpart shall cause to be discharged into the atmosphere from any stationary gas turbine, any gases which contain nitrogen oxides in excess of:

$$STD = 0.0075 \frac{(14.4)}{Y} + F$$

where:

STD = allowable ISO corrected (if required as given in §60.335(b)(1)) NO<sub>x</sub> emission concentration (percent by volume at 15 percent oxygen and on a dry basis),

Y = manufacturer's rated heat rate at manufacturer's rated load (kilojoules per watt hour) or, actual measured heat rate based on lower heating value of fuel as measured at actual peak load for the facility. The value of Y shall not exceed 14.4 kilojoules per watt hour, and

F = NO<sub>x</sub> emission allowance for fuel-bound nitrogen as defined in paragraph (a)(4) of this section.

- (2) No owner or operator subject to the provisions of this subpart shall cause to be discharged into the atmosphere from any stationary gas turbine, any gases which contain nitrogen oxides in excess of:

$$STD = 0.0150 \frac{(14.4)}{Y} + F$$

where:

STD = allowable ISO corrected (if required as given in §60.335(b)(1)) NO<sub>x</sub> emission concentration (percent by volume at 15 percent oxygen and on a dry basis),

Y = manufacturer's rated heat rate at manufacturer's rated peak load (kilojoules per watt hour), or actual measured heat rate based on lower heating value of fuel as measured at actual peak load for the facility. The value of Y shall not exceed 14.4 kilojoules per watt hour, and

F = NO<sub>x</sub> emission allowance for fuel-bound nitrogen as defined in paragraph (a)(4) of this section.

- (3) The use of F in paragraphs (a)(1) and (2) of this section is optional. That is, the owner or operator may choose to apply a NO<sub>x</sub> allowance for fuel-bound nitrogen and determine the appropriate F-value in accordance with paragraph (a)(4) of this section or may accept an F-value of zero.

- (4) If the owner or operator elects to apply a NO<sub>x</sub> emission allowance for fuel-bound nitrogen, F shall be defined according to the nitrogen content of the fuel during the most recent performance test required under §60.8 as follows:

Fuel-bound nitrogen (percent by weight)	F (NO <sub>x</sub> percent by volume)
$N \leq .015$	0
$0.015 < N \leq 0.1$	0.04 (N)
$0.1 < N \leq 0.25$	$0.004 + 0.0067(N - 0.1)$
$N > 0.25$	0.005

Where:

N = the nitrogen content of the fuel (percent by weight).

or:

Manufacturers may develop and submit to EPA custom fuel-bound nitrogen allowances for each gas turbine

model they manufacture. These fuel-bound nitrogen allowances shall be substantiated with data and must be approved for use by the Administrator before the initial performance test required by §60.8. Notices of approval of custom fuel-bound nitrogen allowances will be published in the Federal Register.

- (b) N/A
- (c) Stationary gas turbines with a heat input at peak load equal to or greater than 10.7 gigajoules per hour (10 million Btu/hour) but less than or equal to 107.2 gigajoules per hour (100 million Btu/hour) based on the lower heating value of the fuel fired, shall comply with the provisions of paragraph (a)(2) of this section.
- (d) Stationary gas turbines with a manufacturer's rated base load at ISO conditions of 30 megawatts or less except as provided in §60.332(b) shall comply with paragraph (a)(2) of this section.
- (e) Stationary gas turbines with a heat input at peak load equal to or greater than 10.7 gigajoules per hour (10 million Btu/hour) but less than or equal to 107.2 gigajoules per hour (100 million Btu/hour) based on the lower heating value of the fuel fired and that have commenced construction prior to October 3, 1982 are exempt from paragraph (a) of this section.
- (f) Stationary gas turbines using water or steam injection for control of NO<sub>x</sub> emissions are exempt from paragraph (a) when ice fog is deemed a traffic hazard by the owner or operator of the gas turbine.
- (g) N/A
- (h) N/A
- (i) Exemptions from the requirements of paragraph (a) of this section will be granted on a case-by-case basis as determined by the Administrator in specific geographical areas where mandatory water restrictions are required by governmental agencies because of drought conditions. These exemptions will be allowed only while the mandatory water restrictions are in effect.
- (j) Stationary gas turbines with a heat input at peak load greater than 107.2 gigajoules per hour that commenced construction, modification, or reconstruction between the dates of October 3, 1977, and January 27, 1982, and were required in the September 10, 1979, Federal Register(44 FR 52792) to comply with paragraph (a)(1) of this section, except electric utility stationary gas turbines, are exempt from paragraph (a) of this section.
- (k) Stationary gas turbines with a heat input greater than or equal to 10.7 gigajoules per hour (10 million Btu/hour) when fired with natural gas are exempt from paragraph (a)(2) of this section when being fired with an emergency fuel.
- (l) Regenerative cycle gas turbines with a heat input less than or equal to 107.2 gigajoules per hour (100 million Btu/hour) are exempt from paragraph (a) of this section.

#### **40 C.F.R. § 60.333 Standard for sulfur dioxide.**

On and after the date on which the performance test required to be conducted by §60.8 is completed, every owner or operator subject to the provision of this subpart shall comply with one or the other of the following conditions:

- (a) No owner or operator subject to the provisions of this subpart shall cause to be discharged into the atmosphere from any stationary gas turbine any gases which contain sulfur dioxide in excess of 0.015 percent by volume at 15 percent oxygen and on a dry basis.
- (b) No owner or operator subject to the provisions of this subpart shall burn in any stationary gas turbine any fuel which contains total sulfur in excess of 0.8 percent by weight (8000 ppmw).

**40 C.F.R. § 60.334 Monitoring of operations.**

- (a) Except as provided in paragraph (b) of this section, the owner or operator of any stationary gas turbine subject to the provisions of this subpart and using water or steam injection to control NO<sub>x</sub> emissions shall install, calibrate, maintain and operate a continuous monitoring system to monitor and record the fuel consumption and the ratio of water or steam to fuel being fired in the turbine.
- (b) The owner or operator of any stationary gas turbine that commenced construction, reconstruction or modification after October 3, 1977, but before July 8, 2004, and which uses water or steam injection to control NO<sub>x</sub> emissions may, as an alternative to operating the continuous monitoring system described in paragraph (a) of this section, install, certify, maintain, operate, and quality-assure a continuous emission monitoring system (CEMS) consisting of NO<sub>x</sub> and O<sub>2</sub> monitors. As an alternative, a CO<sub>2</sub> monitor may be used to adjust the measured NO<sub>x</sub> concentrations to 15 percent O<sub>2</sub> by either converting the CO<sub>2</sub> hourly averages to equivalent O<sub>2</sub> concentrations using Equation F-14a or F-14b in appendix F to part 75 of this chapter and making the adjustments to 15 percent O<sub>2</sub>, or by using the CO<sub>2</sub> readings directly to make the adjustments, as described in Method 20. If the option to use a CEMS is chosen, the CEMS shall be installed, certified, maintained and operated as described in 40 C.F.R. § 60.334(b)(1), (2) or (3) as applicable.
- (c) For any turbine that commenced construction, reconstruction or modification after October 3, 1977, but before July 8, 2004, and which does not use steam or water injection to control NO<sub>x</sub> emissions, the owner or operator may, but is not required to, for purposes of determining excess emissions, use a CEMS that meets the requirements of paragraph (b) of this section. Also, if the owner or operator has previously submitted and received EPA, State, or local permitting authority approval of a procedure for monitoring compliance with the applicable NO<sub>x</sub> emission limit under § 60.332, that approved procedure may continue to be used.
- (d) The owner or operator of any new turbine constructed after July 8, 2004, and which uses water or steam injection to control NO<sub>x</sub> emissions may elect to use either the requirements in paragraph (a) of this section for continuous water or steam to fuel ratio monitoring or may use a NO<sub>x</sub> CEMS installed, certified, operated, maintained, and quality-assured as described in paragraph (b) of this section.
- (e) The owner or operator of any new turbine that commences construction after July 8, 2004, and which does not use water or steam injection to control NO<sub>x</sub> emissions, may, but is not required to, elect to use a NO<sub>x</sub> CEMS installed, certified, operated, maintained, and quality-assured as described in paragraph (b) of this section. Other acceptable monitoring approaches include periodic testing approved by EPA or the State or local permitting authority or continuous parameter monitoring as described in paragraph (f) of this section.
- (f) The owner or operator of a new turbine that commences construction after July 8, 2004, which does not use water or steam injection to control NO<sub>x</sub> emissions may, but is not required to, perform continuous parameter monitoring as follows:
  - (1) For a diffusion flame turbine without add-on selective catalytic reduction controls (SCR), the owner or operator shall define at least four parameters indicative of the unit's NO<sub>x</sub> formation characteristics and shall monitor these parameters continuously.
  - (2) For any lean premix stationary combustion turbine, the owner or operator shall continuously monitor the appropriate parameters to determine whether the unit is operating in low-NO<sub>x</sub> mode.
  - (3) For any turbine that uses SCR to reduce NO<sub>x</sub> emissions, the owner or operator shall continuously monitor appropriate parameters to verify the proper operation of the emission controls.
  - (4) N/A
- (g) The steam or water to fuel ratio or other parameters that are continuously monitored as described in paragraphs (a), (d) or (f) of this section shall be monitored during the performance test required under § 60.8, to establish acceptable values and ranges. The owner or operator may supplement the performance test data with engineering analyses,

design specifications, manufacturer's recommendations and other relevant information to define the acceptable parametric ranges more precisely. The owner or operator shall develop and keep on-site a parameter monitoring plan which explains the procedures used to document proper operation of the NO<sub>x</sub> emission controls. The plan shall include the parameter(s) monitored and the acceptable range(s) of the parameter(s) as well as the basis for designating the parameter(s) and acceptable range(s). Any supplemental data such as engineering analyses, design specifications, manufacturer's recommendations and other relevant information shall be included in the monitoring plan.

- (h) The owner or operator of any stationary gas turbine subject to the provisions of this subpart:
- (1) Shall monitor the total sulfur content of the fuel being fired in the turbine, except as provided in paragraph (h)(3) of this section. The sulfur content of the fuel must be determined using total sulfur methods described in §60.335(b)(10). Alternatively, if the total sulfur content of the gaseous fuel during the most recent performance test was less than 0.4 weight percent (4000 ppmw), ASTM D4084–82, 94, D5504–01, D6228–98, or Gas Processors Association Standard 2377–86 (all of which are incorporated by reference-see §60.17), which measure the major sulfur compounds may be used; and
  - (2) Shall monitor the nitrogen content of the fuel combusted in the turbine, if the owner or operator claims an allowance for fuel bound nitrogen ( *i.e.* , if an F-value greater than zero is being or will be used by the owner or operator to calculate STD in §60.332). The nitrogen content of the fuel shall be determined using methods described in §60.335(b)(9) or an approved alternative.
  - (3) Notwithstanding the provisions of paragraph (h)(1) of this section, the owner or operator may elect not to monitor the total sulfur content of the gaseous fuel combusted in the turbine, if the gaseous fuel is demonstrated to meet the definition of natural gas in §60.331(u), regardless of whether an existing custom schedule approved by the administrator for subpart GG requires such monitoring. The owner or operator shall use one of the following sources of information to make the required demonstration:
    - (i) The gas quality characteristics in a current, valid purchase contract, tariff sheet or transportation contract for the gaseous fuel, specifying that the maximum total sulfur content of the fuel is 20.0 grains/100 scf or less; or
    - (ii) Representative fuel sampling data which show that the sulfur content of the gaseous fuel does not exceed 20 grains/100 scf. At a minimum, the amount of fuel sampling data specified in section 2.3.1.4 or 2.3.2.4 of appendix D to part 75 of this chapter is required.
  - (4) For any turbine that commenced construction, reconstruction or modification after October 3, 1977, but before July 8, 2004, and for which a custom fuel monitoring schedule has previously been approved, the owner or operator may, without submitting a special petition to the Administrator, continue monitoring on this schedule.
- (i) The frequency of determining the sulfur and nitrogen content of the fuel shall be as follows:
- (1) *Fuel oil.* N/A
  - (2) *Gaseous fuel.* Any applicable nitrogen content value of the gaseous fuel shall be determined and recorded once per unit operating day. For owners and operators that elect not to demonstrate sulfur content using options in paragraph (h)(3) of this section, and for which the fuel is supplied without intermediate bulk storage, the sulfur content value of the gaseous fuel shall be determined and recorded once per unit operating day.
  - (3) *Custom schedules.* Please refer to 40 C.F.R. § 60.334(i)(3)
- (j) For each affected unit that elects to continuously monitor parameters or emissions, or to periodically determine the fuel sulfur content or fuel nitrogen content under this subpart, the owner or operator shall submit reports of excess emissions and monitor downtime, in accordance with §60.7(c). Excess emissions shall be reported for all periods of unit operation, including startup, shutdown and malfunction. For the purpose of reports required under §60.7(c), periods of excess emissions and monitor downtime that shall be reported are defined as follows:

(1) Nitrogen oxides.

(i) For turbines using water or steam to fuel ratio monitoring:

- (A) An excess emission shall be any unit operating hour for which the average steam or water to fuel ratio, as measured by the continuous monitoring system, falls below the acceptable steam or water to fuel ratio needed to demonstrate compliance with §60.332, as established during the performance test required in §60.8. Any unit operating hour in which no water or steam is injected into the turbine shall also be considered an excess emission.
- (B) A period of monitor downtime shall be any unit operating hour in which water or steam is injected into the turbine, but the essential parametric data needed to determine the steam or water to fuel ratio are unavailable or invalid.
- (C) Each report shall include the average steam or water to fuel ratio, average fuel consumption, ambient conditions (temperature, pressure, and humidity), gas turbine load, and (if applicable) the nitrogen content of the fuel during each excess emission. You do not have to report ambient conditions if you opt to use the worst case ISO correction factor as specified in §60.334(b)(3)(ii), or if you are not using the ISO correction equation under the provisions of §60.335(b)(1).

(ii) If the owner or operator elects to take an emission allowance for fuel bound nitrogen, then excess emissions and periods of monitor downtime are as described in paragraphs (j)(1)(ii)(A) and (B) of this section.

- (A) An excess emission shall be the period of time during which the fuel-bound nitrogen (N) is greater than the value measured during the performance test required in §60.8 and used to determine the allowance. The excess emission begins on the date and hour of the sample which shows that N is greater than the performance test value, and ends with the date and hour of a subsequent sample which shows a fuel nitrogen content less than or equal to the performance test value.
- (B) A period of monitor downtime begins when a required sample is not taken by its due date. A period of monitor downtime also begins on the date and hour that a required sample is taken, if invalid results are obtained. The period of monitor downtime ends on the date and hour of the next valid sample.

(iii) For turbines using NO<sub>x</sub> and diluent CEMS:

- (A) An hour of excess emissions shall be any unit operating hour in which the 4-hour rolling average NO<sub>x</sub> concentration exceeds the applicable emission limit in §60.332(a)(1) or (2). For the purposes of this subpart, a “4-hour rolling average NO<sub>x</sub> concentration” is the arithmetic average of the average NO<sub>x</sub> concentration measured by the CEMS for a given hour (corrected to 15 percent O<sub>2</sub> and, if required under §60.335(b)(1), to ISO standard conditions) and the three unit operating hour average NO<sub>x</sub> concentrations immediately preceding that unit operating hour.
- (B) A period of monitor downtime shall be any unit operating hour in which sufficient data are not obtained to validate the hour, for either NO<sub>x</sub> concentration or diluent (or both).
- (C) Each report shall include the ambient conditions (temperature, pressure, and humidity) at the time of the excess emission period and (if the owner or operator has claimed an emission allowance for fuel bound nitrogen) the nitrogen content of the fuel during the period of excess emissions. You do not have to report ambient conditions if you opt to use the worst case ISO correction factor as specified in §60.334(b)(3)(ii), or if you are not using the ISO correction equation under the provisions of §60.335(b)(1).

(iv) For owners or operators that elect, under paragraph (f) of this section, to monitor combustion parameters or parameters that document proper operation of the NO<sub>x</sub> emission controls:

- (A) An excess emission shall be a 4-hour rolling unit operating hour average in which any monitored parameter does not achieve the target value or is outside the acceptable range defined in the parameter monitoring plan for the unit.
  - (B) A period of monitor downtime shall be a unit operating hour in which any of the required parametric data are either not recorded or are invalid.
- (2) Sulfur dioxide. If the owner or operator is required to monitor the sulfur content of the fuel under paragraph (h) of this section:
- (i) For samples of gaseous fuel and for oil samples obtained using daily sampling, flow proportional sampling, or sampling from the unit's storage tank, an excess emission occurs each unit operating hour included in the period beginning on the date and hour of any sample for which the sulfur content of the fuel being fired in the gas turbine exceeds 0.8 weight percent and ending on the date and hour that a subsequent sample is taken that demonstrates compliance with the sulfur limit.
  - (ii) If the option to sample each delivery of fuel oil has been selected, the owner or operator shall immediately switch to one of the other oil sampling options ( *i.e.* , daily sampling, flow proportional sampling, or sampling from the unit's storage tank) if the sulfur content of a delivery exceeds 0.8 weight percent. The owner or operator shall continue to use one of the other sampling options until all of the oil from the delivery has been combusted, and shall evaluate excess emissions according to paragraph (j)(2)(i) of this section. When all of the fuel from the delivery has been burned, the owner or operator may resume using the as-delivered sampling option.
  - (iii) A period of monitor downtime begins when a required sample is not taken by its due date. A period of monitor downtime also begins on the date and hour of a required sample, if invalid results are obtained. The period of monitor downtime shall include only unit operating hours, and ends on the date and hour of the next valid sample.
- (3) *Ice fog*. Each period during which an exemption provided in §60.332(f) is in effect shall be reported in writing to the Administrator quarterly. For each period the ambient conditions existing during the period, the date and time the air pollution control system was deactivated, and the date and time the air pollution control system was reactivated shall be reported. All quarterly reports shall be postmarked by the 30th day following the end of each calendar quarter.
- (4) *Emergency fuel*. Each period during which an exemption provided in §60.332(k) is in effect shall be included in the report required in §60.7(c). For each period, the type, reasons, and duration of the firing of the emergency fuel shall be reported.
- (5) All reports required under §60.7(c) shall be postmarked by the 30th day following the end of each 6-month period.

#### **40 C.F.R. § 60.335 Test methods and procedures.**

Test methods and procedures described in 40 C.F.R. § 60.335 shall be used for conducting the performance test required in 40 C.F.R. § 60.8 and to show compliance with NO<sub>x</sub> and Sulfur dioxide standards in 40 C.F.R. § 60.332 and 40 C.F.R. § 60.333.